

ANNEX B: HISTORICAL RESTORATION DURATION FOR FAULTS ON SECONDARY SIDE OF THE DISTRIBUTION SYSTEM

Outage Type		YEAR 2006	NO. OF INSTANCES	YEAR 2007	NO. OF INSTANCES	AVERAGE	AVE. NO. OF INSTANCES	Threshold Level (hours)
Broken Service Wire	Ave Affected Customers	26	6	19	6	22	6	Within 1.3
	Ave Restoration Time, hours	1.42		1.15		1.28		
Broken Secondary Line	Ave Affected Customers	55	5	62	6	59	6	Within 1.6
	Ave Restoration Time, hours	1.61		1.57		1.59		
Dist. Transformer Outage	Ave Affected Customers	128	3	96	1	112	2	Within 1.8
	Ave Restoration Time, hours	2.48		1.04		1.76		